



1144 Hooper Avenue  
Suite 202  
Toms River, NJ 08753  
Tel: 732-473-3400 Fax: 732-473-3408

## CLARIFICATION

**DATE:** September 4, 2020  
**PROJECT:** Ice Rink at The Club  
**PROJECT NO:** WOOD-00510

### PLEASE BE ADVISED OF THE FOLLOWING CLARIFICATION TO THE DOCUMENTS:

**1. Clarification:**

**Drawing Sheet 6 of 48 (C5.00 – Drainage and Sanitary Sewer Plan).** In addition to Note 1, the Contractor shall include in the base bid 430 LF of 6" sanitary sewer lateral piping at 1% connecting the three plumbing laterals and tying into the existing sanitary sewer on the north side of the Basketball Building. The contractor shall excavate and expose the existing pipe to confirm invert of 104.25 prior to installing the new lateral.

Should you have any questions please feel free to contact our office at (732) 473-3400.

---

M. ELAINE DASTI, P.E.  
GROUP MANAGER