

KAPLAN

GAUNT

DESANTIS

ARCHITECTS

241 MAPLE AVENUE

RED BANK, NEW JERSEY 07701

TELEPHONE 732.842.8021

FAX 732.747.7634

E-MAIL info@kgdarch.com

**REQUEST FOR INFORMATION**  
**TWO RIVER THEATER COMPANY**

RFI: #2  
DATE: February 7, 2018  
FROM: Terminal Construction Corporation  
TO: Jay Appleton, Greyhawk

**REQUEST:**

1. Stair details on Drawing A-4.2.5 are calling for Non-Slip Rubber Treads and Risers. The intermediate landings show Non-Slip Rubber Tile. The Finish is calling out Floor Type F4, which is Polished Concrete. Please review and clarify the Finishes for all Stair Treads, Risers, Floor Levels & Intermediate Platforms.

**RESPONSE:**

[KGD – 2/8/18] Sheet A-4.2.5 depicts general stair details. All treads, risers and landings shall be rubber. Sheet A-6.3.1 has been revised to more clearly indicate the stair finishes.

**REQUEST:**

2. The 2<sup>nd</sup> Floor Reflected Ceiling Plan, Drawing A-1.4.2 shows Recessed Lighting Fixtures in the Office Space Ceilings, example Room Nos. 211 and 212. Please provide detail showing how these Light Fixtures are installed in the ceiling.

**RESPONSE:**

[KGD – 2/8/18] Please see the Finelight “High Performance 4” Aperture” for installation information.

**REQUEST:**

3. Please provide a Section Cut thru the Modesty Glass Floor indicated on Drawing A-1.3.4 which details how this floor is installed within the slabs.

**RESPONSE:**

[KGD – 2/8/18] Please see detail #4 on sheet A-3.2.3, which has been adjusted for legibility. TGP is responsible for the installation of the glass floor within the structure. Please see general details provided by TGP for reference.